Underground Storage Tanks (USTs) Public Record - Summary Information

General Information

Public Record Posted Date: 11/21/2013

Total Number Of Active UST Facilities: 8,223

Total Number Of USTs: 26,401

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 3,153

Inspection Period Dates: 10/1/2012 To: 9/30/2013

Percent Compliance (Combined Measure): 75%

Note: Tank, facility, and on-site inspection information is based on registered regulated Underground Storage Tanks. On-site inspections measure compliance with SOC (Significant Operational Compliance - compliance with federal release detection and release prevention requirements).

Summary Information For Releases

Number Of Confirmed UST Releases: 262

Release Reporting Period Dates 10/1/2012 To: 9/30/2013

Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Corrosion		Phys/Mech Damage		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	146	56%	4	3%	3	2%	59	40%	10	7%	0	0%	1	1%	69	47%
Piping	15	6%	0	0%	0	0%	4	27%	5	33%	0	0%	0	0%	6	40%
Dispenser	39	15%	4	10%	1	3%	7	18%	9	23%	0	0%	1	3%	17	44%
STP**	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	1	0%	0	0%	1	100%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	10	4%	3	30%	3	30%	1	10%	0	0%	0	0%	1	10%	2	20%
Unknown	51	19%	1	2%	0	0%	0	0%	0	0%	0	0%	1	2%	49	96%
Totals	262	100%	12		8		71		24		0		4		143	

Note: Release, source and cause information is based on data from regulated tanks. Source and cause data were collected primarily using forms and reports submitted by Responsible Parties or their agents.

*Additionally, there were 552 confirmed releases from non-regulated USTs, primarily heating oil tanks, during the reporting period.

**STP - Submersible Turbine Pump

To obtain site-specific information on UST releases contact the Regional DENR Office for the county in which the release occurred. To obtain UST compliance information contact the UST Section Central Office.