Determination of Minor Construction Activity

North Carolina Division of Water Quality
Infrastructure Finance Section

Project Applicant:	Town of Green Level
Date:	April 10, 2013
Project Number:	CS370917-01
Estimated Project Cost:	$2,327,548
Estimated Funding Amount:	$633,000

Project Description: The proposed Basil Holt Pump Station and Green Level Outfall Replacement project will replace a pump station and construct a new forcemain to discharge to the East Burlington WWTP. The planned work includes the following: (1) replace the existing 100 gallons per minute (gpm) Basil Holt Pump Station with a new 400 gpm pump station to mate with the forcemain to Burlington; (2) extend the Otter Creek forcemain approximately 375 feet to a new discharge point to gravity flow to Basil Holt Pump Station; (3) abandon approximately 2,700 linear feet (l.f.) of the Herman Johnson Pump Station forcemain and move the discharge point to gravity flow into Basil Holt Pump Station; (4) add approximately 260 l.f. of gravity sewer to connect Hwy 49 gravity sewer discharge to Basil Holt Pump Station to redirect flow from the Green Level Outfall and plug the outfall; and (5) construct approximately 16,300 l.f. of 8-inch forcemain from the Basil Holt Pump Station to the East Burlington WWTP.

The above named applicant intends to apply for assistance from the State Revolving Fund program to construct the wastewater facilities described above. The North Carolina Division of Water Quality (DWQ) has conducted a review of the project in accordance with the procedures (NCAC 15A Subchapter 1C) for conformance with the North Carolina Environmental Policy Act. The DWQ has determined that this project is below the minor construction activities threshold outlined in 15A NCAC 01C .0408; therefore, the project is exempt from inter-agency review, and the preparation of additional environmental documents is not required.

This determination shall become effective upon its distribution by DWQ and will be available on the DWQ Infrastructure Finance Section's website (http://portal.ncdenr.org/web/wq/ifs/er/fonsis). This determination can be revoked at any time adverse information is made available. The documentation to support this decision will be on file with the North Carolina Department of Environment and Natural Resources, Division of Water Quality, Infrastructure Finance Section, and is available for public scrutiny upon request.

Comments concerning this decision may be addressed to Ms. Jennifer Haynie, Facilities Evaluation Unit, Infrastructure Finance Section, Division of Water Quality, 1633 Mail Service Center, Raleigh, North Carolina 27699, or she can be reached by phone at (919) 707-9173.

Sincerely,

Kim H. Colson, P.E., Chief
Infrastructure Finance Section
Division of Water Quality