Underground Storage Tanks (USTs) Public Record - Summary Information

General Information

Public Record Posted Date: 11/19/2012

Total Number Of Active UST Facilities: 8,333

Total Number Of USTs: 26,738

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 3,027

Inspection Period Dates: 10/1/2011 To: 9/30/2012

Percent Compliance (Combined Measure): 74%

Note: Tank, facility, and on-site inspection information is based on registered regulated Underground Storage Tanks. On-site inspections measure compliance with SOC (Significant Operational Compliance - compliance with federal release detection and release prevention requirements).

Summary Information For Releases

Number Of Confirmed UST Releases: 251*

Release Reporting Period Dates 10/1/2011 To: 9/30/2012

Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Corrosion		Phys/Mech Damage		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	134	53%	2	1%	4	3%	44	33%	4	3%	0	0%	6	4%	74	55%
Piping	13	5%	0	0%	0	0%	1	8%	4	31%	0	0%	1	8%	7	54%
Dispenser	35	14%	4	11%	2	6%	3	9%	6	17%	0	0%	1	3%	19	54%
STP**	2	1%	0	0%	0	0%	1	50%	1	50%	0	0%	0	0%	0	0%
Delivery Problem	3	1%	1	33%	0	0%	0	0%	2	67%	0	0%	0	0%	0	0%
Other	5	2%	0	0%	1	20%	0	0%	2	40%	0	0%	1	20%	1	20%
Unknown	59	24%	0	0%	0	0%	0	0%	1	2%	0	0%	0	0%	58	98%
Totals	251	100%	7		7		49		20		0		9		159	

Note: Release, source and cause information is based on data from regulated tanks. Source and cause data were collected primarily using forms and reports submitted by Responsible Parties or their agents.

*Additionally, there were 462 confirmed releases from non-regulated USTs, primarily heating oil tanks, during the reporting period.

**STP - Submersible Turbine Pump

To obtain site-specific information on UST releases contact the Regional DENR Office for the county in which the release occurred. To obtain UST compliance information contact the UST Section Central Office.