Determination of Minor Construction Activity

North Carolina Division of Water Quality
Construction Grants and Loans Section

Project Applicant: City of Marion
Date: April 29, 2009
Project Number: 2W370406-02
Estimated Project Cost: $ 6,601,364
Estimated Funding Amount: $ 2,601,364

Project Description: The proposed project generally consists of improvements to the City of Marion's Corpening Creek Wastewater Treatment Plant including the installation of a new headwork assembly with mechanical bar screen, grit removal system, and triplex submersible influent pump station, chemical feec equipment, new digester and numerous yard piping modifications and other appurtenances. The project titled Catawba Creek Wastewater Pump Sations and Force Main generally consists of the installation of a new mechanical screening device with bypass channel, 2 duplex submersible wastewater pump station, a chemical feed system, approximately 12,635 linear feet of 10-inch force main with all associated appurtenances and the abandonment of the City of Marion's existing Catawba River Wastewater Treatment Plant.

The above named applicant intends to apply for assistance from the State Revolving Fund program associated with the American Recovery and Reinvestment Act of 2009 to construct the wastewater facilities described above. The North Carolina Division of Water Quality (DWQ) has conducted a review of the project in accordance with the procedures (NCAC 15A Subchapter 1C) for conformance with the North Carolina Environmental Policy Act. The DWQ has determined that this project is a minor construction activity, and that the preparation of additional environmental documents is not required.

This determination shall become effective upon its distribution by DWQ. This determination can be revoked at any time adverse information is made available. The documentation to support this decision will be on file with the North Carolina Department of Environment and Natural Resources, Division of Water Quality, Construction Grants and Loans Section, and is available for public review at www.nccgl.net.

Comments concerning this decision may be addressed to Mr. Kim H. Colson, P.E., Assistant Chief, Construction Grants and Loans Section, Division of Water Quality, 1633 Mail Service Center, Raleigh, North Carolina 27699-1633, or he may be reached by phone at (919) 715-6212.

Sincerely,

Daniel M. Blaisdell

Daniel M. Blaisdell, P.E., Chief
Construction Grants and Loans Section
Division of Water Quality