Underground Storage Tanks (USTs) Public Record - Summary Information

General Information

Public Record Posted Date: 11/29/2011

Total Number Of Active UST Facilities: 8,419

Total Number Of USTs: 27,012

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 3,113

Inspection Period Dates: 10/1/2010 To: 9/30/2011

Percent Compliance (Combined Measure): 73%

Note: Tank, facility, and on-site inspection information is based on registered regulated Underground Storage Tanks. On-site inspections measure compliance with SOC (Significant Operational Compliance - compliance with federal release detection and release prevention requirements).

Summary Information For Releases

Number Of Confirmed UST Releases: 201*

Release Reporting Period Dates 10/1/2010 To: 9/30/2011

Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Corrosion		Phys/Mech Damage		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	100	50%	10	10%	3	3%	37	37%	4	4%	0	0%	4	4%	42	42%
Piping	14	7%	1	7%	1	7%	1	7%	4	29%	0	0%	1	7%	6	43%
Dispenser	29	14%	2	7%	1	3%	1	3%	7	24%	1	3%	0	0%	17	59%
STP**	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	3	1%	1	33%	1	33%	0	0%	1	33%	0	0%	0	0%	0	0%
Other	9	4%	0	0%	3	33%	0	0%	2	22%	0	0%	2	22%	2	22%
Unknown	46	23%	0	0%	0	0%	0	0%	1	2%	0	0%	1	2%	44	96%
Totals	201	100%	14		9		39		19		1		8		111	

Note: Release, source and cause information is based on data from regulated tanks. Source and cause data were collected primarily using forms and reports submitted by Responsible Parties or their agents.

*Additionally, there were 449 confirmed releases from non-regulated USTs, primarily heating oil tanks, during the reporting period.

**STP - Submersible Turbine Pump

To obtain site-specific information on UST releases contact the Regional DENR Office for the county in which the release occurred. To obtain UST compliance information contact the UST Section Central Office.