Determination of Minor Construction Activity

North Carolina Division of Water Quality
Construction Grants and Loans Section

Project Applicant:	Town of Wallace
Date:	November 4, 2011
Project Number:	CS370445-05
Estimated Project Cost:	$255,000
Estimated Funding Amount:	$250,000

Project Description: The proposed project consists of the rehabilitation of terra cotta gravity sewer with the installation of the same size cured-in-place-pipe (CIPP) in four distinct project areas. The Sloan project consists of installing approximately 1,700 linear feet (l.f.) of 8-inch CIPP along Sloan Street between Westbrook Street and Raleigh Road. The Pine project consists of installing approximately 1,070 l.f. of 6-inch CIPP along Pine Street between Orange Street and Raleigh Road. The Westbrook-Teachey project consists of installing approximately 200 l.f. of 8-inch CIPP between Westbrook Street and Teachey Road. The Dixon-Graham project consists of installing approximately 810 l.f. of 8-inch and 320 l.f. of 10-inch CIPP located along the length of Dixon Street and along Graham Street between Dixon and Teachey Road. In all, the quantity of gravity sewer proposed for CIPP is approximately 320 linear feet (l.f.) of 10-inch, 2,710 l.f. of 8-inch, and 1,070 l.f. of 6-inch gravity sewer.

The above named applicant intends to apply for assistance from the State Revolving Fund program to construct the wastewater facilities described above. The North Carolina Division of Water Quality (DWQ) has conducted a review of the project in accordance with the procedures (NCAC 15A Subchapter 1C) for conformance with the North Carolina Environmental Policy Act. The DWQ has determined that this project is a minor construction activity, and that the preparation of additional environmental documents is not required.

This determination shall become effective upon its distribution by DWQ and will be available on the DWQ Construction Grants and Loans Section's website (http://portal.ncdenr.org/web/wq/cgls/er/fonsis). This determination can be revoked at any time adverse information is made available. The documentation to support this decision will be on file with the North Carolina Department of Environment and Natural Resources, Division of Water Quality, Construction Grants and Loans Section, and is available for public scrutiny upon request.

Comments concerning this decision may be addressed to Ms. Jennifer Haynie, Facility Evaluation Unit, Construction Grants and Loans Section, Division of Water Quality, 1633 Mail Service Center, Raleigh, North Carolina 27699, or she can be reached by phone at (919) 715-6223.

Sincerely,

Kim H. Colson, P.E., Chief
Construction Grants and Loans Section
Division of Water Quality